

NCB:

NCB-ACT-SACT-20-68, Contractor Support for NATO HQ SACT Solar Power System Installation and LED Lighting Conversion for Headquarters Supreme Allied Command Transformation

Reference:

Q & A # 2

Date of Issue:

29 Sept 2020

The following questions were raised with respect to subject RB. Responses are to provide clarification.

| Questions | Responses |
|--|--|
| 1. Will we be required to perform the LED portion of the solicitation off-hours? Normal business hours for us are 8AM - 4PM Mon-Fri. | We are not requiring work outside of their normal working hours. Facilities can accommodate 0630 to 1730 Mon-Fri. Per the SOW deliverables, a detailed schedule will be provided by the contractor which we can use to manage work around the customer. IF during the construction phase they need to work outside normal working hours, we can accommodate as long as we get notified in advance. |
| 2. Are we required to use the enclosure 4 for past performance or can we submit past performance in our own format? | Any format is acceptable, however, the information requested in Enclosure 4 (Past Performance) must be included and easily identified in the proposal. |
| 3. Are we required to send two emails for the proposals, one for technical and one for price? | Please see para. 11, Contents of Proposal in NCB-ACT-SACT-20-68 for instructions on submitting proposals. |
| 4. Are recessed can lights on 3rd-5th floor part of project? | No, The can lights on 3rd- 5th floors that were off are old and obsolete. The removal of them are an ongoing project that we are working to complete. |
| 5. Are there ballasts for the emergency lights? | The emergency lighting do have an emergency ballast that they run on. The lights with emergency ballast are shown on the electrical prints. |