

Request for Proposal

RFP-ACT-SACT-26-29

Q&A #1

From Site Visit

Question #	Answer
1. Will there be a need to move the sprinkler system?	No, the sprinkler system will not need to be moved from the ceiling.
2. Will the existing flooring need to rip out in order to install carpet?	No, carpet will be laid over existing concrete flooring. Minor repairs to the flooring may need to be completed before laying the carpet.